

Seminole County
Facility Capacity Impact Assessment
Basic Information - Worksheet 1 of 5

Applicant Name:	JUDITH D. SMITH
Project Name:	HISTORIC OVIEDO COLORED SCHOOLS MUSEUM
Contact Phone/Email:	407-234-3374 OBSERVEANDREMEBER@GMAIL.COM
Date Completed:	7-21-2024

SECTION 1 - Proposed FUTURE LAND USE Evaluation (Other than PD)		
Items	Entries	Units
A. Enter proposed Future Land Use - Insert initials to right. <i>If proposed FLU is PD, skip this section and complete SECTION 2 at bottom of page.</i>	JS	Any FLU except PD
B. Enter Max. Allowable Residential Dwelling Units/Acre under the proposed FLU		Whole # Units/Acre
C. Enter Max. Allowable Non-Residential FAR (floor area ratio) under proposed FLU	0%	Percent
D. Enter Gross Acres - NOTE: The gross acres are used to project the maximum potential development and may exceed final allowable net buildable acres.		Acres
E. RESIDENTIAL TEST FIGURE - Potential residential unit maximum*	0	Units Lines (B x D)
F. NON-RESIDENTIAL TEST FIGURE - Potential non-residential sq/ft max.*	0	Sq Ft (C x D x 43560)

* Test figures are used only to provide a preliminary calculation of projected facility demands.

SECTION 2 - Proposed PLANNED DEVELOPMENT (PD) Evaluation Only		
Items	Entries	Units
PD Proposed Future Land Use - (<i>If other than PD, complete SECTION 1 above.</i>)	PD	FLU
RESIDENTIAL TEST FIGURE - Enter proposed unit count*	0	Units
NON-RESIDENTIAL TEST FIGURE - Enter proposed square feet*	0	Square Feet

* Test figures are used only to provide a preliminary calculation of projected facility demands.

Facility Capacity Impact Assessment - Worksheet 2 of 5

Potable Water Facilities

Applicant Name	Project Name	Well? Check b , make no entries
JUDITH D. SMITH	HISTORIC OVIEDO COLORED SCHOOLS MUSEUM	<input type="checkbox"/>
Enter Utility Name:	SEMINOLE COUNTY WATER/SEWER	
Enter Utility Contacted Name:	ENVIROMENTA SERVICES	
Enter Contact's Phone Number:	407-665-2143	


- To identify the utility serving a parcel, go to:

http://www.seminolecountyfl.gov/cms_application_Placeholder.aspx?page=MyResidentPage **or go to**

<http://gis2.seminolecountyfl.gov/InformationKiosk/>

- For Seminole County water/sewer information, contact Environmental Services, Business Office: 407-665-2110

- For well permitting, contact the Seminole County Building Division, 407-665-7050, and the Health Department, 407-665-3604

Line	Facility Capacity Status	Entries	Notes/Units
1	Enter Available Capacity provided by Utility Contact:		Available permitted capacity in millions of gallons/day (mgd)
	NOTE: In place of an Available Capacity figure, check here that a letter from the utility confirming ability to serve is attached.		Letter attached in place of demand calculations

POTABLE WATER DEMAND CALCULATIONS

Residential Demand Calculation - For Seminole County utility service, enter 350 gals per day per unit as the residential level of service. For City/Private utility service, enter the level of service if provided by the utility.

(* Residential Test Figure is from Worksheet 1 of 5)

Line	Residential Test Figure *	Level Of Service (LOS) gpd	Demand	Notes/Units
2	0		0.000	(Test Figure x LOS per unit) / 1.0 mgd

Non-Residential Demand Calculation - For Seminole County utility service, enter 0.1 gals per day per square foot as the non-residential level of service. For City/Private utility service, enter the level of service if provided by the utility.

(* Non-Residential Test Figure is from Worksheet 1 of 5)

Line	Non-Res Test Figure*	Level Of Service (LOS) gpd	Demand	Notes/Units
3	0		0.000	(Test Figure x LOS per unit) / 1.0 mgd

4	Total Proposed Water Demand	0.000	Total Demand mgd (Lines 2 + 3)
5	Remaining Capacity	0.000	Remaining permitted capacity mgd (Lines 1 - 4)

Facility Capacity Impact Assessment - Worksheet 3 of 5

Sanitary Sewer Facilities

Applicant Name	Project Name	Septic? Check b , make no entries
JUDITH D. SMITH	HISTORIC OVIEDO COLORED SCHOOLS MUSEUM, INC	<input checked="" type="checkbox"/>
Enter Utility Name:	SEMINOLE COUNTY ENVIRONMENTAL SERVICES	
Enter Utility Contacted Name:	BECKY NOGGLE, OSP SR. COORDINATOR	
Enter Contact's Phone Number:	407-665-2143	

- To identify the utility serving a parcel, go to:

http://www.seminolecountyfl.gov/cms_application_Placeholder.aspx?page=MyResidentPage **or go to**

<http://gis2.seminolecountyfl.gov/InformationKiosk/>

- For Seminole County water/sewer information, contact Environmental Services, Business Office: 407-665-2110

- For onsite sewage and disposal, contact the Seminole County Department of Health, Environmental Health: 407-665-3604

Line	Facility Capacity Status	Entries	Notes/Units
1	Enter Available Capacity provided by Utility Contact:		Available permitted capacity in millions of gallons/day (mgd)
	NOTE: In place of an <u>Available Capacity</u> figure, check here that a letter from the utility confirming ability to serve is attached.	<input checked="" type="checkbox"/>	Letter attached in place of demand calculations

SANITARY SEWER DEMAND CALCULATIONS

Residential Demand Calculation - For Seminole County utility service, enter 300 gals per day per unit as the residential level of service. For City/Private utility service, enter the level of service if provided by the utility.

(* Residential Test Figure is from Worksheet 1 of 5)

Line	Residential Test Figure *	Level Of Service (LOS) gpd	Demand	Notes/Units
2	0		0.000	(Test Figure x LOS per unit) / 1.0 mgd

Non-Residential Demand Calculation - For Seminole County utility service, enter 0.1 gals per day per square foot as the non-residential level of service. For City/Private utility service, enter the level of service if provided by the utility.

(* Non-Residential Test Figure is from Worksheet 1 of 5)

Line	Non-Res Test Figure*	Level Of Service (LOS) gpd	Demand	Notes/Units
3	0		0.000	(Test Figure x LOS per unit) / 1.0 mgd

4	Total Proposed Sewer Demand	0.000	Total Demand mgd (Lines 2 + 3)
5	Remaining Capacity	0.000	Remaining permitted capacity mgd (Lines 1 - 4)

Facility Capacity Impact Assessment - Worksheet 4 of 5

County-wide Solid Waste Facilities

NOTE: Residential unit count serves as an estimate for both residential and non-residential solid waste disposal demand. A calculation based on non-residential square feet alone is not required to complete the application.

Applicant Name	Project Name
JUDITH D. SMITH	HISTORIC OVIEDO COLORED SCHOOLS MUSEUM, INC.

Residential Test Figure (WorkSheet 1)	Multiply	Persons per Household	Equals	Calculated Residential Population
0	x	2.6	=	0

FACILITY	Items	Entries	Notes/Units
Landfill	NOTE: A Level of Service (LOS) of 4.3 lb/capita/day, when applied to new residential units, captures both the residential waste component and the non-residential component associated with increased growth that is disposed of daily at the landfill. The remaining landfill capacity as of 2013 is: 20,202,000 tons. *		
1	Calculated Residential Population (from above)	0	Persons
2	Adopted LOS pounds per person per day	4.3	Lb/cap/day
3	Proposed Annual Landfill Demand	0.0	Tons (Lines 1 x 2 x 365)/2000

Transfer Station	NOTE: A Level of Service (LOS) of 4.0 lb/capita/day, when applied to new residential units, captures both the residential waste component and the non-residential component associated with increased growth that is processed daily through the transfer station. The transfer station capacity as of 2013 is: 2500 tons/day. *		
1	Calculated Residential Population (from above)	0	Persons
2	Adopted LOS pounds per person per day	4.0	Lb/cap/day
3	Proposed Daily Transfer Station Demand	0.000	Tons (Lines 1 x 2)/2000

* Based on information provided by the Seminole County Solid Waste Management Division in 2013. The County's remaining Landfill capacity and Transfer Station processing capacity is projected to be sufficient through 2060 and 2050 respectively at current growth rates and therefore the calculation of a deduction from the remaining capacity of either is unnecessary. The projection is redone with each Evaluation and Appraisal Report.

Facility Capacity Impact Assessment - Worksheet 5 of 5

County-wide Recreation and Open Space Facilities

NOTE: A calculation based on non-residential square feet alone is not required to complete the application.

Applicant Name	Project Name
JUDITH D. SMITH	HISTORIC OVIEDO COLORED SCHOOLS MUSEUM, INC

Residential Test Figure	Multiply	Persons per Household	Equals	Calculated Residential Population
0	x	2.6	=	0

RECREATION	Items	Entries	Notes/Units
Total Acres	NOTE: Level of Service (LOS) for total developed and passive recreation lands is 3.6 acres per 1000 population equating to .0036 acres per person. Remaining acreage: 1,394*		
1	Calculated Residential Population (from above):	0	Persons
2	Adopted LOS acres per person	3.6	Acres/1000 Pop
3	Proposed Total Acres Demand	0.000	Acres (Lines 1 x 2)/1000

Developed Acres	NOTE: Level of Service (LOS) for developed recreation land is 1.8 acres per 1000 population equating to .0018 acres per person. Remaining Acreage: 178*		
1	Calculated Residential Population (from above):	0	Persons
2	Adopted LOS acres per person	1.8	Acres/1000 Pop
3	Proposed Developed Acres Demand	0.000	Acres (Lines 1 x 2)/1000

* Based on 2010 adopted CIE Update. The County's remaining Total and Developed acreage is projected to be sufficient through 2030 at current growth rates and therefore the calculation of a deduction from remaining capacity of either is unnecessary. The projection is redone with each Evaluation and Appraisal Report.

TO: JUDITH SMITH
observeandremember@gmail.com

FROM: SEMINOLE COUNTY WATER & SEWER
BECKY NOGGLE, OSP SR COORDINATOR
(407) 665-2143

DATE: 7/9/2024

RE: NEW SEWER SERVICE CONNECTION
2170 James Dr

APPROVED

FEES SUBJECT TO RATE CHANGE AFTER 90 DAYS:

\$ 3175.00	SEWER CONNECTION FEE
\$ 110.00	UNDERGROUND UTILITY PERMIT
\$ <u>60.00</u>	REFUNDABLE DEPOSIT
\$ 3,345.00	TOTAL

COMMENTS:

- It will be the responsibility of the Home Owner to hire a contractor to do the actual connection.
- Our office will need to review and approve your sewer lateral proposal from your contractor/engineer.
- Payment of ALL fees must be received prior to start of work. Please make checks payable to Seminole County Water and Sewer.
- Miscellaneous Plumbing Permit should be pulled through Seminole County Building Department @ 407-665-7050 to apply. The Miscellaneous Permit is required in order to have your work inspected from the house to the connection point. The Underground Utility Permit is required for the Environmental Services inspector to inspect the work on the actual sewer lateral.
- Contact Environmental Health to submit for a septic tank abandonment permit. 407-665-3605