

SEMINOLE COUNTY GOVERNMENT
 1101 EAST FIRST STREET, WEST WING
 SANFORD, FLORIDA 32771

Comment Document – Initial Submittal

The DRC meeting allows 20 minutes per project to discuss and clarify any comments of concern. Additional comments or deletion of comments may result from discussions at the DRC meeting. The DRC Agenda can be found [HERE](#).

PROJECT NAME:	LEXUS OF OVIEDO - REZONE	PROJ #: 26-20000001
APPLICATION FOR:	PZ - REZONE (EXCL PD)	
APPLICATION DATE:	1/21/26	
RELATED NAMES:	Z2026-01	
PROJECT MANAGER:	KAITLYN APGAR (407) 665-7377	
PARCEL ID NO.:	29-21-31-300-0170-0000	
NO OF ACRES	1.65	
BCC DISTRICT	1-Bob Dallari	
LOCATION	ON THE NORTHWEST CORNER OF CAMP RD AND W SR 426	
FUTURE LAND USE-	IND	
SEWER UTILITY	SEMINOLE COUNTY UTILITIES	
WATER UTILITY	SEMINOLE COUNTY UTILITIES	
APPLICANT:	CONSULTANT:	
M. REBECCA WILSON LOWNDES 215 N EOLA DR ORLANDO FL 32801 (407) 418-6250	N/A	

County staff members have reviewed the subject development project and offer the following comments. The comments below are a compilation of comments from the ePlan review system. These items need responses with further information, data, explanation or revision of plans and documents before project approval.

Please itemize any and all revisions made to the development plan in addition to those made in response to staff comments; include a statement in your response to comments that no additional revisions have been made to the site plan beyond those stated.

For questions regarding the ePlan process, please consult the Electronic Plan Review Applicant User Guide <http://www.seminolecountyfl.gov/core/fileparse.php/3321/urllt/ePlanApplicantUserGuide.pdf>

See comments within the comment document for any fees due, as fees may be due for different aspects of your development project. Fees showing in ePlan reflect Planning & Development review or revision fees only.

State Permits that may be required:

FDOT, FDEP- UTILITIES, SJRWMD, ENVIRONMENTAL REPORTS, ARCHEOLOGICAL REPORTS, FDEP- ENVIRONMENTAL, SJRWMD- ENVIRONMENTAL, FFW, IF APPLICABLE.

AGENCY/DEPARTMENT COMMENTS

	REVIEWED BY	TYPE	STATUS
1.	Buffers and CPTED	A full buffer will be done at the time of site plan review.	Info Only
2.	Building Division	This proposed use is a Change of Occupancy for this building/ location. Standard permitting will apply and must be delt with prior to use of building/ structure. - Full signed/ sealed plans sets must be submitted for approval via a formal permit package submission. - Any necessary, or proposed modifications must be properly permitted.	Info Only
3.	Environmental Services	According to our records, it appears as though there is no utility easement over the existing Seminole County owned commercial water meters/DDCVA. Everything else on the site appears to be privately owned/maintained. Please contact the property owner (or authorized representative) and have them provide us any documentation that there is an existing utility easement over this infrastructure. If none exists, then please have the property owner (or authorized representative) provide a sketch and legal description (signed/sealed by a professional surveyor) of the proposed utility easement so that we can begin the process to getting this completed. A signed/sealed sketch and legal description is all that we would require to be completed at this time as the rest of the process can take a while to complete. We require 15 ft wide utility easements along the centerline of our potable water mains/fire hydrants and 10 ft wide utility easements along the centerline of our potable water meters/service lines. Please see the file "SCUD 2780 West State Road 426 Survey" in the Resources folder on eplan for reference on the rough dimensions of the utility easement that we're looking for.	Unresolved
4.	Environmental Services	Seminole County will remain as the water/sewer provider for this development.	Info Only
5.	Planning and Development	Prior to staff scheduling the required public hearings, the Applicant must conduct a community meeting. The community meeting shall be held at least twenty (20) calendar days prior to the scheduled public hearing or public meetings in a location accessible to the public, near the subject property, and in a facility that is ADA compliant. After the Community Meeting has commenced the applicant will be required to upload or email the project manager the community meeting minutes, sign-in sheet, and addresses.	Unresolved

6.	Planning and Development	Please email the legal description in a word document to kapgar@seminolecountyfl.gov	Unresolved
7.	Public Safety - Fire Marshal	Type of use and size of building may require fire sprinklers and fire alarms.	Info Only
8.	Public Safety - Fire Marshal	Adequate water supply with fire flow calculations for fire protection (hydrants) shall be provided per section 18.3 and 18.4 of NFPA 1.	Info Only
9.	Public Safety - Fire Marshal	Fire department access road shall have an unobstructed width of not less than 20 ft in accordance with the specifications of NFPA 1, Section 18.2.3.5.1.1	Info Only
10.	Public Safety - Fire Marshal	"All the following items shall be acknowledged and added to the site plan sheets as note: 1.Fire department access roads provided at the start of a project and shall be maintained throughout construction. (NFPA 1, 16.1.4). 2.A second entrance/exit might be required per AHJ if the response time for emergency is exceeded per NFPA 1, Section 18.2.3.3 Multiple Access Roads. 3.A water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material accumulates. This applies to both commercial and residential developments. (NFPA 1, 16.4.3.1). 4.Where underground water mains and hydrants are to be provided, they shall be installed, completed, and in service prior to construction work. (NFPA 1, 16.4.3.1.3). 5.Fire flow testing shall be performed in accordance with NFPA 291, recommended practice for fire flow testing. 6.A 36 in. clear space shall be maintained around the circumference of fire hydrants and a clear space of not less than 60 in. (1524 mm) shall be provided in front of each hydrant connection having a diameter greater than 2 1/2 in. NFPA 1, 18.5.7. 7.Hydrant shall be marked with a blue reflector in the roadway in accordance with NFPA 1, chapter 18.5.10. 8.Access to gated Subdivisions or Developments shall provide Fire Department access through an approved SOS and Seminole County Knox Key Switch. NFPA 1, 18.2.2.2"	Info Only
11.	Public Works - Engineering	No issues with the rezone with respect to traffic as long as the existing access is maintained.	Info Only
12.	Public Works - Engineering	No concerns for rezone in regard to drainage as long as no additional impervious area is proposed. If additional impervious area is proposed, the existing drainage system will have to be evaluated or altered as needed.	Info Only
13.	Public Works - Impact Analysis	No review required.	Info Only

DEPARTMENT PROJECT STATUS AND CONTACT

This section shows the reviewers of this project from the various departments.

Department	Reviewer	Email	Contact	Status
Buffers and CPTED	Kaitlyn Apgar	kapgar@seminolecountyfl.gov	407-665-7377	Approved
Building Division	Phil Kersey	pkersey@seminolecountyfl.gov	407-665-7460	Approved
Comprehensive Planning	Maya Athanas	mathanas@seminolecountyfl.gov	407-665-7388	Approved
Environmental - Impact Analysis	Becky Noggle	bnoggle@seminolecountyfl.gov	407-665-2143	No Review Required
Environmental Services	James Van Alstine	jvanalstine@seminolecountyfl.gov	407-665-2014	Corrections Required
Natural Resources	Sarah Harttung	sharttung@seminolecountyfl.gov	407-665-7391	Review Complete Recommend Approval
Planning and Development	Kaitlyn Apgar	kapgar@seminolecountyfl.gov	407-665-7377	Corrections Required
Public Safety - Fire Marshal	Matthew Maywald	mmaywald@seminolecountyfl.gov	407-665-5177	Approved
Public Works - Engineering	Jim Potter	jpotter@seminolecountyfl.gov	407-665-5764	Approved
Public Works - Impact Analysis	Arturo Perez	Aperez07@seminolecountyfl.gov	407-665-5716	No Review Required

The next submittal, as required below, will be your:

1st RESUBMITTAL

DATE	RESUBMITTAL FEE DUE	ROUTE TO THESE STAFF MEMBERS FOR FURTHER REVIEW:
2/19/2026	The application fee allows for the initial submittal plus two resubmittals. <i>Note: No resubmittal fee for Small Site Plans or Special Exceptions</i>	James Van Alstine, Kaitlyn Apgar
<p>The initial application fee allows for the initial submittal review plus two resubmittal reviews. For the fourth review and each subsequent review, the resubmittal fees are as follows:</p> <p>Major Review (3+ reviewers remaining) – 50% of original application fee</p> <p>Minor Review (1-2 reviewers remaining) – 25% of original application fee</p> <p>Summary of Fees: http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/fee-information/fee-summary.shtml</p> <p>NOTE: Other fees may be due. See comments for any additional fees due for your development project. (example: Addressing fee)</p>		

Upon completion of your plan review process, Planning and Development staff must authorize and stamp plans for construction use. Once you receive an approval letter from Seminole County, the site contractor must contact Seminole County Planning and Development Inspections to schedule a pre-construction conference prior to the start of any site work. Upon issuance of the site permit, your approved drawings and/or documents will be released to you through the ePlan System. For questions regarding this process, please consult the Electronic Plan Review Applicant User Guide <http://www.seminolecountyfl.gov/core/fileparse.php/3321/urlt/ePlanApplicantUserGuide.pdf>

Cities:

Altamonte Springs	(407) 571-8000	www.altamonte.org
Casselberry	(407) 262-7700	www.casselberry.org
Lake Mary	(407) 585-1449	www.lakemaryfl.com
Longwood	(407) 260-3440	www.longwoodfl.org
Oviedo	(407) 971-5555	www.cityofoviedo.net
Sanford	(407) 688-5000	www.sanfordfl.gov
Winter Springs	(407) 327-1800	www.winterspringsfl.org

Other Agencies:

Florida Dept of Transportation	FDOT		www.dot.state.fl.us
Florida Dept of Enviro Protection	FDEP	(407) 897-4100	www.dep.state.fl.us
St. Johns River Water Mgmt Dist	SJRWMD	(407) 659-4800	www.sjrwmd.com
Health Department	Septic	(407) 665-3621	

Other Resources:

Flood Prone Areas
Watershed Atlas
Seminole Co. Property Appraiser

www.seminolecountyfl.gov/gm/building/flood/index.aspx
www.seminole.wateratlas.usf.edu
www.scpafl.org