

SEMINOLE COUNTY GOVERNMENT

1101 EAST FIRST STREET, WEST WING
SANFORD, FLORIDA 32771

The DRC Agenda can be found [here](#).

PROJECT NAME:	REMINGTON PARK COMMERCIAL - PRE-APPLICATION	PROJ #: 25-80000118
APPLICATION FOR:	DR - PRE-APPLICATION DRC	
APPLICATION DATE:	10/30/25	
RELATED NAMES:	EP RYAN RENARDO	
PROJECT MANAGER:	KAITLYN APGAR (407) 665-7377	
PARCEL ID NO.:	27-21-31-511-0000-0050++	
PROJECT DESCRIPTION	PROPOSED SITE PLAN FOR A DRIVE-THRU RESTAURANT ON 1.74 ACRES IN THE PD/C-1 ZONING DISTRICT LOCATED ON THE SOUTH SIDE OF REMINGTON DR, WEST OF ALAFAYA TRL	
NO OF ACRES	1.74	
BCC DISTRICT	1: DALLARI	
CURRENT ZONING	C-1/PD	
LOCATION	ON THE SOUTH SIDE OF REMINGTON DR, WEST OF ALAFAYA TRL	
FUTURE LAND USE-	COM	
APPLICANT:	CONSULTANT:	
CHRIS HUGHES WEKIVA CAPITAL PARTNERS 941 W MORSE BLVD WINTER PARK FL 32789 (407) 256-1943 C.D.HUGHES3@GMAIL.COM	RYAN RENARDO R-SQUARED ENGINEERING 10312 BLOOMINGDALE AVE STE 108 RIVERVIEW FL 33578 (727) 741-3536 RYAN@RSQUAREDENG.COM	

Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time-to-time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review.


The development project review will be completed utilizing Electronic Plan Review (ePlan). For questions regarding this process, please consult the Electronic Plan Review Applicant User Guide that can be found [here](#).

PROJECT MANAGER COMMENTS


- The subject property has a Future Land Use of Commercial (COM) and a zoning designation of PD (Planned Development) and C-1, Retail Commercial.
- Remington Commercial Park PD was approved on July 25, 2000. The proposed plan is not consistent with the Development Order (DO); thus a rezone is required. A rezone to C-1, Retail Commercial, would be consistent with the surrounding area.
- If the proposed development intends to combine the three (3) parcels, a replat will be required.

PROJECT AREA ZONING AND AERIAL MAPS

Future Land Use: COM



Zoning: C-1 and PD



Aerial



AGENCY/DEPARTMENT COMMENTS

	REVIEWED BY	TYPE	STATUS
1.	Buffers and CPTED	100 percent of landscaped areas are required to be irrigated. See the following link for requirements https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT14LASCBUOPSP_S30.14.18LAPLIRPLSURE	Info Only
2.	Buffers and CPTED	A full buffer review will be done at time of site plan/final engineering review. Buffer requirements will be calculated based on project intensity. Per Sec. 30.14.6, Upon submittal of plans, please provide 1. Net buildable Area. 2. Hours of Operation. 3. Floor Area Ratio. 4. Impervious Surface Ratio. 5. Building Height in feet in order to calculate required buffers.	Info Only
3.	Buffers and CPTED	The buffer is calculated based on project intensity versus surrounding property (or roadway, as applicable) intensity. The subject property will be assigned a Land Use Intensity (LUI) rating based on proposed density/intensity. The adjacent properties will be estimated per guidelines in the code (vacant vs developed). See the link below for calculating LUI. Sec. 30.14.6, https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT14LASCBUOPSP_S30.14.6DELAUSCLIN	Info Only
4.	Buffers and CPTED	The applicable LUI will yield a buffer opacity when evaluated in accordance with the Required Buffers Tables, see the link to SCLDC Sec. 30.14.7 below https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT14LASCBUOPSP_S30.14.7REBU	Info Only
5.	Buffers and CPTED	The buffer opacity corresponds to a certain width, plant unit groups per 100 feet, and structural enhancements (as applicable). The standard bufferyards/widths are located at the following link: https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT14LASCBUOPSP_S30.14.5STBUPEAD .	Info Only
6.	Buffers and CPTED	General buffer and landscaping concepts will be required to be shown on the Master Development Plan if rezoning to a PD per SCLDC Sec. 30.8.5.5.	Info Only
7.	Buffers and CPTED	A parking buffer shall be required where a parking lot, or parking structure, drive aisle, and/or loading dock is located within twenty-five (25) feet of the boundary of a residential district or Future Land Use designation. Such buffer shall be in addition to any buffer required under Section 30.14.7.	Info Only
8.	Buffers and CPTED	Please see SCLDC. Sec. 30.14.13 for parking lot landscaping https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT14LASCBUOPSP_S30.14.13PALOLA	Info Only
9.	Building Division	11/6/25: - Standard permitting will apply. - Each structure, building will require a separate permit package. Example: buildings, structure, stand-alone awnings, retaining walls,	Info Only

		fence/ gate systems, signage, dumpster enclosures, etc.....	
10.	Comprehensive Planning	Future Land Use of COM across all proposed parcels. The maximum FAR is noted in the associated entitlement documents. The purpose and intent for this land use is to identify locations for a variety of commercial uses including neighborhood and community shopping centers, convenience stores, retail sales, highway oriented commercial, and other commercial services.	Info Only
11.	Environmental - Impact Analysis	Seminole County is the Water and Sewer service provider for this project. Capacity reservation will be required.	Info Only
12.	Environmental Services	This development is within Seminole County's sanitary sewer service area and will be required to connect. There's a manhole on the south side of Remington Drive near the northwest property line of parcel 27-21-31-511-0000-0050.	Info Only
13.	Environmental Services	This development is within Seminole County's reclaim irrigation service area and will be required to connect. There's a 12" PVC reclaim water main running along the centerline of Alafaya Trail.	Info Only
14.	Environmental Services	Be advised that Alafaya Trail is an FDOT right of way so any utility construction work within this area will require an FDOT utility permit.	Info Only
15.	Environmental Services	If you would like to see a utility GIS map of the area, please submit a request form by following the provided link: https://www.seminolecountyfl.gov/departments-services/utilities/utilities-engineering/utility-gis-information.shtml . This page can also be navigated to from our official website via Departments and Services -> Utilities -> Utilities Engineering -> Utility GIS Information. Once there, there will be a bold CLICK HERE in blue near the center of the page. A request form will be sent out to our department inbox for review, and we'll get back to you with a response as soon as we can. This is for the purpose of tracking the release of sensitive utility GIS map information.	Info Only
16.	Environmental Services	This development is within Seminole County's potable water service area and will be required to connect. The nearest connection point is a 20" DI potable water main running along the west side of Alafaya Trail. There is also a 10" PVC potable water main running along the north side of Remington Drive.	Info Only
17.	Natural Resources	Specimen tree: Live oak, magnolia, bald cypress and longleaf pine trees twenty-four (24) inches DBH or greater. SCLDC Chapter 2	Info Only
18.	Natural Resources	Historic tree: Any live oak, bald cypress, or longleaf pine thirty-six (36) inches or greater DBH that is determined by Seminole County to be of such unique and intrinsic value to the general public because of its size, age, historic association or ecological value as to justify this classification. Prior to removal of any live oak, bald cypress, or longleaf pine thirty-six (36) inches or greater DBH, a report from a certified arborist must be submitted detailing the condition of the tree, if the condition of tree has a rating over 3 or above, the tree must be inspected by the Natural Resource Officer prior to removal. Any tree	Info Only

		designated a Florida State Champion shall likewise be within this definition.	
19.	Natural Resources	Please provide a sealed or certified tree survey prepared by a professional surveyor, completed within the past 2 years. Show the location, DBH, common name, and, if applicable, indicate specimen tree status of all protected and preserved trees. SCLDC 60.10(b)(1)	Info Only
20.	Natural Resources	Dead or declining trees, as determined by a certified arborist, are exempt from arbor regulations. SCLDC 60.4(f)	Info Only
21.	Natural Resources	Trees less than six (6) inches DBH and palm trees are exempt from arbor regulations. SCLDC 60.4(h)	Info Only
22.	Natural Resources	Impervious surfaces placed beneath the drip line of any preserved tree shall not exceed forty (40) percent of the drip-line area and shall not be placed closer than six feet from the trunk of any such trees without prior approval from the Development Services Director, or designee. SCLDC 60.8(f)	Info Only
23.	Natural Resources	All preserved trees shall have their natural soil level maintained. Tree wells and/or planter islands shall be provided, if necessary, to maintain the natural existing soil level of at least seventy-five (75) percent of the drip line. SCLDC 60.8(g)	Info Only
24.	Natural Resources	Replacement of non-specimen trees shall be based on a one-to-one ratio of the cumulative DBH of the trees to be removed to the cumulative caliper of the trees to be installed. Specimen trees shall be replaced on a two-to-one ratio of the cumulative caliper of the trees to be installed to the cumulative DBH of the trees removed. SCLDC 60.9(d)(1)	Info Only
25.	Natural Resources	The cumulative DBH of specimen trees preserved on site shall count two (2) to one (1) toward meeting the total replacement requirement. SCLDC 60.9(d)(6a) The cumulative DBH of protected non-specimen trees preserved on site shall count two (2) to one (1) toward meeting the total replacement requirement.	Info Only
26.	Natural Resources	Trees located within a designated conservation area shall not count toward replacement requirements. SCLDC 60.9(d)(7)	Info Only
27.	Natural Resources	In the case of a subdivision development, an application for an arbor permit shall accompany the preliminary subdivision plan of said subdivision and shall be submitted to the Development Review Division for review. SCLDC 60.10(a)(1)	Info Only
28.	Natural Resources	In the case of any development which requires site plan approval by the Planning and Zoning Commission, the Board of County Commissioners, or both; permits for removal, relocation or replacement of trees covered under this Chapter 60 shall be obtained by making application at the time of site plan submittal. SCLDC 60.10(a)(2)	Info Only
29.	Natural Resources	The review may include, but need not be limited to, a field check of the site and referral of the application for recommendations to other appropriate administrative departments or agencies. SCLDC 60.10(d)	Info Only
30.	Natural Resources	No subdivision may be approved that would result in the removal of over seventy-five (75) percent of existing trees,	Info Only

		with trunk diameters of six (6) inches or greater, from any site, unless the Planning Manager finds that the development of the site would be severely restricted. Special consideration and credit will be given to the retention of trees having a trunk diameter of twenty-four (24) inches or larger. Special consideration will be given for waterfront features and shoreline protection as specified in Chapter 71 of this Code. SCLDC 35.61(b)	
31.	Natural Resources	According to the county wetland maps, wetlands are possibly located on the western side of the property. ***Please be advised the county wetland maps can be used only as guidelines and cannot be used to make jurisdictional wetlands determination. A field determination can be made by a qualified environmental scientist. **	Info Only
32.	Natural Resources	Wetland boundaries need to be delineated by a wetlands specialist and approved by Seminole County and staff of FDEP if residential not in the WRPA or SJRWMD if residential in the WRPA or if in a Commercial plat. The plat must show the approved wetland line and provide the date and name of the SJRWMD reviewer.	Info Only
33.	Natural Resources	A 15-foot minimum, 25-foot average undisturbed upland buffer must be provided from all approved jurisdictional wetland boundaries.	Info Only
34.	Natural Resources	Conservation easements dedicated to Seminole County will be required over the wetlands and required buffers, and all property within the 100 year flood plain.	Info Only
35.	Natural Resources	Resources for wetland information: St. Johns River Water Management District: www.sjrwmd.com Florida Department of Environmental Protection: www.dep.state.fl.us Seminole County Map Resources: www.seminolecountyfl.gov Wetland and Flood Prone: Under ONLINE SERVICES / Interactive Maps / Information Kiosk Quadrangles: DEPARTMENTS/ Information Technologies / GIS / Maps available for viewing / Wetland quadrangle maps. Seminole County Property Appraiser Map Resources: http://www.scpafl.org Zoning, Future Land Use, FEMA, Aerials	Info Only
36.	Planning and Development	INFORMATIONAL: County staff has reviewed the subject project based on the information you have provided to us and have compiled the following information for your use. Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time to time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review. Seminole County Land Development Code: http://www.seminolecountyfl.gov/guide/codes.asp Seminole County Planning & Development: http://www.seminolecountyfl.gov/gm/	Info Only
37.	Planning and Development	The Planned Commercial Development (PCD) on the subject property was approved on July 25, 2000. As stated	Info Only

		in DO #2000-0024, Remington Commercial Park PCD, Lot 5 is proposed as a single lot and single-phase development. The proposed development in this pre-application is not consistent with the DO approved for the PCD; and therefore, will require a rezone.	
38.	Planning and Development	Required parking will be in accordance with SCLDC Sec. 30.11.3 for quantities. Please also see Sec. 30.11.6 for design. • Up to eighty (80) percent of spaces provided may have a minimum net area of one hundred sixty-two (162) square feet, a minimum width of nine feet (9), and a minimum length of eighteen feet (18). • A minimum of twenty (20) percent of required off-street parking space shall consist of a minimum net area of two hundred (200) square feet with a minimum width of ten (10) feet and a minimum length of twenty (20) feet.	Info Only
39.	Planning and Development	Bicycle parking will be required in accordance with SCLDC Sec. 30.11.7.3 General Bicycle Parking Requirements.	Info Only
40.	Planning and Development	If outdoor lighting is proposed, a photometric plan may be required at site plan. Outdoor lighting requires a separate permit. Outdoor lighting fixtures shall be located no less than fifty (50) feet from any property having a residential future land use designation or a residential zoning classification. Illumination onto adjacent properties shall not exceed five-tenths (0.5) foot-candles. All fixtures, including security lighting, must be cutoff fixtures. (SCLDC 30.15.1 https://library.municode.com/fl/seminole_county/codes/land_development_code?nodeId=SECOLADECO_CH30ZORE_PT15OULIRE)	Info Only
41.	Planning and Development	The proposed project is subject to Site Plan Review Process: SCLDC Chapter 40. Information can be found at: http://cdn.seminolecountyfl.gov/departments-services/development-services/planning-development/development-processes-requirements/index.stml	Info Only
42.	Planning and Development	1st Step – Rezone - This process requires a public hearing before the Planning and Zoning (P&Z) Commission, followed by a public hearing before the Board of County Commissioners (BCC). The timeline may range between 4 to 6 months, depending on staff review timelines and Board agenda scheduling deadlines. 2nd step – Approval of Site Plan/Final Engineering Plans. 3rd Step – Final Plat: The Final Plat may be reviewed concurrently with the Final Engineering Plan; however, it cannot be approved until an approval letter for the Final Engineering Plan has been issued. Building permits for vertical construction can be issued after the Final Plat is approved.	Info Only
43.	Planning and Development	Community Meeting Procedures Section 30.3.5.3 • Prior to staff scheduling the required public hearings, the Applicant must conduct a community meeting in	Info Only

		compliance with SCLDC Sec.30.3.5.3 – Community Meeting Procedure (Ordinance #2021-30). The community meeting shall be held at least twenty (20) calendar days prior to the scheduled public hearing or public meetings in a location accessible to the public, near the subject property, and in a facility that is ADA compliant. • Prior to scheduling a Community Meeting, please provide the project manager with a draft community meeting notification flyer to ensure the flyer meets the requirements of SCLDC Sec. 30.3.4.2(e) - Community Meeting Procedure, before mailing out the surrounding neighbors. After the Community Meeting has commenced the applicant will be required to upload or email the project manager the community meeting minutes, sign-in sheet, and addresses).	
44.	Planning and Development	Sec. 30.3.4: Public Notice Procedure for Amendments to the Future Land Use Map, Zoning Map, Non-Residential Variances and Special Exceptions: Placards Placards shall be a minimum of 24"x 36" in size. A minimum of two (2) placards shall be required per property or project. At the discretion of the Division Manager the number of placards on a property or project may be increased. Placards shall be posted at least fifteen (15) days prior to a scheduled public hearing; Placards shall state the time and place of the hearing and the nature of the matter to be discussed; Affidavit of proof of the required publication and placards posting shall be presented to staff prior to the public hearing by the applicant/petitioner/appellant and shall be made a part of the record of the proceeding.	Info Only
45.	Planning and Development	Per the C-1 zoning district and Commercial Future Land Use. the following regulations apply: Maximum Floor Area Ratio (F.A.R.) is 0.35 Minimum required open space is twenty-five (25)%, and Maximum building height is thirty-five (35) feet.	Info Only
46.	Planning and Development	The minimum building setbacks for the C-1 (Retail Commercial) district are as follows: Front- Twenty-five (25) feet Rear- Ten (10) feet Side- Zero (0) feet Side yard setback may be reduced to zero (0) feet except when a side lot line abuts property assigned a residential zoning classification or land use designation. Rear yard setback shall be a minimum of ten (10) feet unless a rear lot line abuts property assigned a residential zoning classification or land use designation.	Info Only
47.	Planning and Development	If the proposed development intends to combine the properties, then a replat will be required. If the proposed development intends to keep the parcels separated, then development within each parcel will have to maintain	Info Only

		setbacks per the zoning district.	
48.	Planning and Development	A 15-foot minimum, 25-foot average undisturbed upland buffer shall be provided from all approved jurisdictional wetland boundaries.	Info Only
49.	Planning and Development	Conservation easements, dedicated to Seminole County, will be required over the wetlands and required buffers as well as lands within the 100 year floodplain during the platting process.	Info Only
50.	Planning and Development	The proposed project is subject to Subdivision Review Process: SCLDC Chapter 35. Information can be found at: http://cdn.seminolecountyfl.gov/departments-services/development-services/planning-development/development-processes-requirements/index.stml	Info Only
51.	Public Safety - Fire Marshal	Type of use and size of building may require fire sprinklers and fire alarms.	Info Only
52.	Public Safety - Fire Marshal	Adequate water supply with fire flow calculations for fire protection (hydrants) shall be provided per section 18.3 and 18.4 of NFPA 1.	Info Only
53.	Public Safety - Fire Marshal	Fire department access road shall have an unobstructed width of not less than 20 ft in accordance with the specifications of NFPA 1, Section 18.2.3.5.1.1	Info Only
54.	Public Safety - Fire Marshal	"All the following items shall be acknowledged and added to the site plan sheets as note: 1.Fire department access roads provided at the start of a project and shall be maintained throughout construction. (NFPA 1, 16.1.4). 2.A second entrance/exit might be required per AHJ if the response time for emergency is exceeded per NFPA 1, Section 18.2.3.3 Multiple Access Roads. 3.A water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material accumulates. This applies to both commercial and residential developments. (NFPA 1, 16.4.3.1). 4.Where underground water mains and hydrants are to be provided, they shall be installed, completed, and in service prior to construction work. (NFPA 1, 16.4.3.1.3). 5.Fire flow testing shall be performed in accordance with NFPA 291, recommended practice for fire flow testing. 6.A 36 in. clear space shall be maintained around the circumference of fire hydrants and a clear space of not less than 60 in. (1524 mm) shall be provided in front of each hydrant connection having a diameter greater than 21/2 in. NFPA 1, 18.5.7. 7.Hydrant shall be marked with a blue reflector in the roadway in accordance with NFPA 1, chapter 18.5.10. 8.Access to gated Subdivisions or Developments shall provide Fire Department access through an approved SOS and Seminole County Knox Key Switch. NFPA 1, 18.2.2.2"	Info Only
55.	Public Works - Engineering	Based on FEMA FIRM Map the site or portions of the site appear to lie in the floodplain. Seminole County does not allow fill in the floodplain without equal volumetric compensation.	Info Only
56.	Public Works - Engineering	The proposed project is located within the Howell Creek drainage basin.	Info Only
57.	Public Works - Engineering	Based on SCS Soil Survey GIS overlays, the site generally has generally poorly draining class soils.	Info Only

58.	Public Works - Engineering	The drainage for the site is not clear. An appropriate outfall will need to be demonstrated or the site will have to hold one of the following as applicable; The entire 25-year, 24-hour storm event volume if the site is not land locked or entire 100-year, 24-hour storm event onsite without discharge if it is determined to be land locked.	Info Only
59.	Public Works - Engineering	Conservation easements, dedicated to Seminole County, will be required over all property within the post-development 100 year flood plain.	Info Only
60.	Public Works - Engineering	Based on 1 ft. contours, the topography of the site appears to slope west.	Info Only
61.	Public Works - Engineering	Based on a preliminary review, the site appears to outfall to the existing Remington drainage system.	Info Only
62.	Public Works - Engineering	A detailed drainage analysis will be required at final engineering.	Info Only
63.	Public Works - Engineering	A FEMA LOMR (Letter Of Map Revision) may be required. For more information, contact FEMA at www.fema.gov	Info Only
64.	Public Works - Engineering	A permit from the St. John's River Water Management District or Florida Department of Environmental Protection is generally required for projects with more than 5,000 sq. ft. of new impervious or 4,000 sq. ft. of new building for a total of 9,000 sq. ft. of new impervious surface. For more information see www.sjrwmd.com .	Info Only
65.	Public Works - Engineering	A National Pollutant Discharge Elimination System (NPDES) Permit is required for all projects that disturb greater than one acre. (http://cfpub.epa.gov/npdes/home.cfm?program_id=45)	Info Only
66.	Public Works - Engineering	Driveway location/separation is not in accordance with the County Access Management Standards. The separation is required to be 200-foot on a local roadway. 330' on a Collector or Arterial roadway.	Info Only
67.	Public Works - Engineering	Sidewalks shall be required in accordance with the code. At final engineering approval a note to the plans that states "Any sidewalk less than 5' wide (6' along arterial or collector roads) or any broken sidewalk within Seminole County ROW abutting property frontage will be brought into compliance with Seminole County regulations.	Info Only
68.	Public Works - Engineering	The proposed access onto Alafaya Trail does not meet separation requirements. Please note Alafaya Trail is an FDOT road and any permits would have to go through them for work in the right of way.	Info Only
69.	Public Works - Impact Analysis	A Traffic Impact Study (TIS) may be required for this project if the new net external trip generation for the site generates more than 50 weekday peak hour trips based on the ITE Trip Generation Manual, 11th Ed . The TIS is to be prepared in accordance with the County's Traffic Study Requirements for Concurrency guidelines. A methodology for the TIS is to be submitted to County Staff for review and approval prior to submittal of the TIS itself. Contact Mr. Arturo J. Perez, P.E. for requirements at (407) 665-5716 or via email to aperez07@seminolecountyfl.gov .	Info Only

DEPARTMENT PROJECT STATUS AND CONTACT

This section shows the reviewers of this project from the various departments.

Department	Reviewer	Email	Contact
Buffers and CPTED	Kaitlyn Apgar	kapgar@seminolecountyfl.gov	407-665-7377
Building Division	Phil Kersey	pkersey@seminolecountyfl.gov	407-665-7460
Comprehensive Planning	Maya Athanas	mathanas@seminolecountyfl.gov	407-665-7388
Environmental - Impact Analysis	Becky Noggle	bnoggle@seminolecountyfl.gov	407-665-2143
Environmental Services	James Van Alstine	jvanalstine@seminolecountyfl.gov	407-665-2014
Natural Resources	Sarah Harttung	sharttung@seminolecountyfl.gov	407-665-7391
Planning and Development	Kaitlyn Apgar	kapgar@seminolecountyfl.gov	407-665-7377
Public Safety - Fire Marshal	Matthew Maywald	mmaywald@seminolecountyfl.gov	407-665-5177
Public Works - Engineering	Jim Potter	jpotter@seminolecountyfl.gov	407-665-5764
Public Works - Impact Analysis	Arturo Perez	Aperez07@seminolecountyfl.gov	407-665-5716

RESOURCE INFORMATION

Seminole County Land Development Code:

https://library.municode.com/fl/seminole_county/codes/land_development_code

Seminole County Comprehensive Plan:

<http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/codes-regulations/comprehensive-plan/index.stml>

Development Services:

<http://www.seminolecountyfl.gov/departments-services/development-services/>

Seminole County Property Appraiser Maps:

<https://map.scpafl.org/>

Seminole County Wetland Information:

<http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/forms-applications-resources/wetl-dock-information.stml>

Wekiva Consistency form:

<https://www.seminolecountyfl.gov/docs/default-source/pdf/WekivaRiverAreaConsistencyFormNovember2024ADA.pdf>

FEMA LOMR (Letter of Map Revision):

www.fema.gov

Cities:

Altamonte Springs	(407) 571-8150	www.altamonte.org
Casselberry	(407) 262-7751	www.casselberry.org
Lake Mary	(407) 585-1369	www.lakemaryfl.com
Longwood	(407) 260-3462	www.longwoodfl.org
Oviedo	(407) 971-5775	www.cityofoviedo.net
Sanford	(407) 688-5140	www.sanfordfl.gov
Winter Springs	(407) 327-5963	www.winterspringsfl.org

Other Agencies:

Florida Dept of Transportation	FDOT		www.dot.state.fl.us
Florida Dept of Enviro Protection	FDEP	(407) 897-4100	www.dep.state.fl.us
St. Johns River Water Mgmt Dist	SJRWMD	(407) 659-4800	www.sjrwmd.com
Health Department	Septic	(407) 665-3605	www.floridahealth.gov

Other Resources:

Flood Prone Areas	www.seminolecountyfl.gov/gm/building/flood/index.aspx
Watershed Atlas	www.seminole.wateratlas.usf.edu