

SEMINOLE COUNTY GOVERNMENT
1101 EAST FIRST STREET, 2ND FLOOR, WEST WING
SANFORD, FLORIDA 32771

Please review the comments below. If you determine that you would like to be scheduled for a 20 minute meeting with the Development Review Committee, please email your request to attend to devrevdesk@seminolecountyfl.gov or call (407) 665-7372 no later than noon on Friday, 9/29/2023, in order to place you on the Wednesday, 10/4/2023 meeting agenda.

MEETINGS ARE NOW BEING HELD IN A HYBRID FORMAT (IN-PERSON AND VIRTUALLY ON ZOOM). IF YOU REQUEST A MEETING, YOU MUST INDICATE WHETHER YOU WOULD LIKE TO ATTEND THE MEETING IN-PERSON OR REMOTELY VIA ZOOM.

The DRC Agenda can be found [HERE](#).

PROJECT NAME:	ALEXANDER AVE LOT 3 - PRE-APPLICATION	PROJ #: 23-80000124
APPLICATION FOR:	DR - PRE-APPLICATION DRC	
APPLICATION DATE:	9/15/23	
RELATED NAMES:	EP PENNY SEATER	
PROJECT MANAGER:	KATHY HAMMEL (407) 665-7389	
PARCEL ID NO.:	35-19-30-517-1000-0030	
PROJECT DESCRIPTION	PROPOSED SITE PLAN TO BUILD A SINGLE-FAMILY HOME ON 0.11 ACRES IN THE R-1 ZONING DISTRICT LOCATED ON THE EAST SIDE OF ALEXANDER AVE, SOUTH OF 20TH ST	
NO OF ACRES	0.11	
BCC DISTRICT	5: HERR	
CURRENT ZONING	R-1	
LOCATION	ON THE EAST SIDE OF ALEXANDER AVE, SOUTH OF 20TH ST	
FUTURE LAND USE-	LDR	
APPLICANT:	CONSULTANT:	
PENNY SEATER HABITAT FOR HUMANITY SEMINOLE PO BOX 181010 CASSELBERRY FL 32718 (407) 696-5855 CONSTRUCTION@HABITAT-SA.ORG	N/A	

Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time to time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review.

The development project review will be completed utilizing Electronic Plan Review (ePlan). For questions regarding this process, please consult the Electronic Plan Review Applicant User Guide that can be found [HERE](#).

PROJECT MANAGER COMMENTS

- The proposed site is located within the “Lockhart” Target Area.
- The Applicant can proceed to apply for a building permit to place a single family home on the subject site.
- The subject site is a parcel of record.

AGENCY/DEPARTMENT COMMENTS

No.	Group Name	Reviewer Comment	Status
1.	Building Division	Any building construction and/or modification will require Building permits and engineered plans to meet the current 7th ED (2020) Florida Building Codes.	Informational
2.	Comprehensive Planning	The Future Land Use (FLU) is Low Density Residential which allows for single family at a maximum of four dwelling units per net buildable acre or permitted up to seven dwelling units per net buildable acre in compliance with the provisions of Policy FLU 10.1 Affordable and Workforce Housing Density and Intensity Bonuses.	Informational
3.	Planning and Development	INFORMATIONAL: County staff has reviewed the subject project based on the information you have provided to us and have compiled the following information for your use. Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time to time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review. Seminole County Land Development Code: http://www.seminolecountyfl.gov/guide/codes.asp Seminole County Planning & Development: http://www.seminolecountyfl.gov/gm/	Informational
4.	Planning and Development	The setbacks for the R-1 (Single- Family Dwelling) zoning district is: 25' Front Yard, 30' Rear yard, 7.5 Side Yard, 25' (15') Side Street.	Informational
5.	Planning and Development	A sidewalk may be required to be installed at the time of building permit.	Informational
6.	Planning and Development	The subject property is within an Economic Development "Lockhart" Target Area.	Informational
7.	Planning and Development	FLU 4.3 (F) - The County will also consider code changes to allow infill development, redevelopment and renovation of existing structures on existing lots of record within Community Development Block Grant eligible Target Area. Case-by-case basis would be at the discretion of the Planning and Development Division Manager, without variances. <u>This provision can be applied when the lot or lots in question were legal lots at time of platting, but do not meet current lot size and setback standards.</u>	Informational
8.	Planning and Development	Parking Space requirements for single family residence are two (2) spaces for each residence. For example, one parking space in the driveway and one parking space in the garage.	Informational
9.	Planning and Development	The minimum lot size in the R-1 (Single Family Dwelling) Zoning District is 700 square feet, and the Minimum width at building line is 70'.	Informational
10.	Planning and Development	Based on the property appraisers it is in the City of Sanford service area, if the City of Sanford states that you are not in their service	Informational

		area for water or sewer then you will need to reach out to the Seminole County Health Department regarding a permit for septic tanks. St. Johns Water Management District would be the division to reach out to regarding well permits.	
11.	Planning and Development	A tree permit will be required for any removal of trees since it is a vacant parcel. If a property owner wants to remove trees outside of the building and utility area during construction of the dwelling unit, then replacement of trees is required. However, if they wait to remove the trees until the structure is occupied (and the parcel is 5 acres or less in size), then they may do as they please without needing a permit or replacing removed trees.	Informational
12.	Planning and Development	There are no setback requirements for a/c units or pool equipment. However, a/c unit and pool equipment are not allowed to be placed within any easement (ex. drainage and utility, etc.).	Informational
13.	Planning and Development	The length of the driveway would be required to be a minimum of twenty-two (22) feet from the edge of the garage to the property line.	Informational
14.	Public Safety - Fire Marshal	Adequate water supply with fire flow calculations for fire protection (hydrants) shall be provided per chapter 18.3 of NFPA 1 (2018).	Informational
15.	Public Safety - Fire Marshal	This project will require 20 ft. fire department access in accordance with NFPA 1, Chapter 18.2.3.5.1.1 (2018 edition).	Informational
16.	Public Works - Engineering	Driveway/ right of way permit must be applied for separately.	Informational
17.	Public Works - Engineering	A detailed drainage analysis will be required at building permit. This must show that there is not adverse drainage to the adjacent lots.	Informational

AGENCY/DEPARTMENT EFORM COMMENTS AND PROJECT STATUS

This section shows the reviewers of this project from the various County agencies. It may also include additional comments for review and response.

Department	Reviewer	Email	Status	Reviewer Comments
Buffers and CPTED	Maya Athanas	mathanas@seminolecountyfl.gov	No Review Required	(407) 665-7388
Planning and Development	Kathy Hammel	khammel@seminolecountyfl.gov	Review Complete	407-665-7389
Public Safety - Fire Marshal	Matthew Maywald	mmaywald@seminolecountyfl.gov	Review Complete	
Comprehensive Planning	Tyler Reed	treed@seminolecountyfl.gov	Review Complete	
Natural Resources	Sarah Harttung	sharttung@seminolecountyfl.gov	No Review Required	
Impact Analysis Coordination	William Wharton	wwharton@seminolecountyfl.gov	No Review Required	
Environmental Services	Paul Zimmerman	pzimmerman@seminolecountyfl.gov	No Review Required	Paul Zimmerman, PE (407) 665-2040
Building Division	Tony Coleman	acoleman@seminolecountyfl.gov	No Review Required	

RESOURCE INFORMATION

Seminole County Land Development Code:

<http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/codes-regulations/>

Seminole County Comprehensive Plan:

<http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/codes-regulations/comprehensive-plan/index.shtml>

Development Services:

<http://www.seminolecountyfl.gov/departments-services/development-services/>

Wekiva Consistency form:

<http://www.seminolecountyfl.gov/core/fileparse.php/3207/urlt/WekivaConReview.pdf>

Seminole County Property Appraiser Maps:

<http://www.scpafl.org>

Seminole County Wetland Information:

<http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/forms-applications-resources/wetl-dock-information.shtml>

FEMA LOMR (Letter of Map Revision):

www.fema.gov

Cities:

Altamonte Springs	(407) 571-8000	www.altamonte.org
Casselberry	(407) 262-7700	www.casselberry.org
Lake Mary	(407) 585-1449	www.lakemaryfl.com
Longwood	(407) 260-3440	www.longwoodfl.org
Oviedo	(407) 971-5555	www.cityofoviedo.net
Sanford	(407) 688-5000	www.sanfordfl.gov
Winter Springs	(407) 327-1800	www.winterspringsfl.org

Other Agencies:

Florida Dept of Transportation	FDOT		www.dot.state.fl.us
Florida Dept of Enviro Protection	FDEP	(407) 897-4100	www.dep.state.fl.us
St. Johns River Water Mgmt Dist	SJRWMD	(407) 659-4800	www.sjrwmd.com
Health Department	Septic	(407) 665-3621	

Other Resources:

Flood Prone Areas	www.seminolecountyfl.gov/gm/building/flood/index.aspx
Watershed Atlas	www.seminole.wateratlas.usf.edu

