Document date: 3/19/2024

### SEMINOLE COUNTY GOVERNMENT

1101 EAST FIRST STREET, 2ND FLOOR, WEST WING SANFORD, FLORIDA 32771

The DRC Agenda can be found HERE.

PROJECT NAME:	SAND LAKE RD - PRE-APPLICATION	PROJ #: 24-80000038	
APPLICATION FOR:	DR - PRE-APPLICATION DRC		
APPLICATION DATE:	3/08/24		
RELATED NAMES:	EP BRENDA PEARCE		
PROJECT MANAGER:	KATHY HAMMEL (407) 665-7389		
PARCEL ID NO.:	08-21-29-524-0100-0000		
PROJECT DESCRIPTION	PROPOSED SPECIAL EXCEPTION FOR A NEV	V WATER METER SYSTEM	
	INSTALLATION ON 0.02 ACRES IN THE PD ZO	NING DISTRICT LOCATED ON	
	THE SOUTH SIDE OF SAND LAKE RD, EAST C		
NO OF ACRES	0.02		
BCC DISTRICT	3-LEE CONSTANTINE		
CURRENT ZONING	PD		
LOCATION	ON THE SOUTH SIDE OF SAND LAKE RD, EAS	ST OF HUNT CLUB BLVD	
FUTURE LAND USE-	PD		
APPLICANT:	CONSULTANT:		
BRENDA PEARCE	N/A		
BLACK & VEATCH/SUNSHINE			
200 WEATHERSFIELD AVE			
ALTAMONTE SPRINGS FL 32714			
(678) 656-5179			
PEARCEB@BV.COM			

Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time to time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review.

The development project review will be completed utilizing Electronic Plan Review (ePlan). For questions regarding this process, please consult the Electronic Plan Review Applicant User Guide that can be found <u>HERE</u>.


#### PROJECT MANAGER COMMENTS

The parcel is located within unincorporated Seminole County and within the Forest Lake Academy Planned Development (PD).

The installation of a pole with an antenna for a new water metering system will require a Major Amendment to allow the use in the PD. A variance to the building/structure height of 35 feet may also be required.

Printed: 3/21/24 3:22 PM Page 1 of 5

# PROJECT AREA ZONING AND AERIAL MAPS





# **AGENCY/DEPARTMENT COMMENTS**

	REVIEWED BY	TYPE	STATUS
1.	Buffers and CPTED	A full buffer review will be done at time of site plan review or review of a special exception.	Info Only
2.	Comprehensive Planning	The Future Land Use is Forest Lake Academy Planned Development (PD) which allows for utilities.	Info Only
3.	Environmental Services	We have no objection to the proposed construction. The construction is located within the Sunshine Service Area.	Info Only
4.	Building Division	Any building construction and/or modification will require Building permits and engineered plans to meet the current 8th ed (2023) Florida Building Codes. No action required at this time.	Info Only
5.	Planning and Development	INFORMATIONAL: County staff has reviewed the subject project based on the information you have provided to us and have compiled the following information for your use. Please be advised, these comments are intended to assist you in finding information that will enable you to prepare for your plan review. They are not intended to replace or exempt you from the applicable Codes and Ordinances as they pertain to your project. These comments are informational only and do not grant any approvals. Also be advised, from time to time Codes and Ordinances are amended and the comments provided only reflect the regulations in effect at the time of review. Seminole County Land Development Code: http://www.seminolecountyfl.gov/guide/codes.asp Seminole	Info Only

Printed: 3/21/24 3:22 PM Page 2 of 5

		County Planning & Development: http://www.seminolecountyfl.gov/gm/	
6.	Planning and Development	Sec. 30.44: Public Notice Procedure for Amendments to the Future Land Use Map, Zoning Map, Non-Residential Variances and Special Exceptions: Community Meeting Procedures Section 30.49.  Prior to staff scheduling the required public hearings, the Applicant must conduct a community meeting in compliance with SCLDC Sec.30.49 Community Meeting Procedure (Ordinance #2021-30). The community meeting shall be held at least twenty (20) calendar days prior to the scheduled public hearing or public meeting in a location accessible to the public, near the subject property, and in a facility that is ADA compliant. Please see attached Community Meeting Procedure document.	Info Only
7.	Planning and Development	Major Amendment Approval Process:  1st step is approval of Major Amendment which involves a public hearing with Planning & Zoning (P&Z), followed by a public hearing with the Board of County Commissioners (BCC). May take between 4-5 months depending on the review and agenda date deadlines.  2nd step is approval of a Site Plan.	Info Only
8.	Public Safety - Fire Marshal	If any actual structure is required (other than the pole) the following shall be required: Fire department access road shall have an unobstructed width of not less than 20 ft in accordance with the specifications of NFPA 1, Section 18.2.3.5.1.1	Info Only
9.	Public Safety - Fire Marshal	If any actual structure is required (other than the pole) the following shall be required: Adequate water supply with fire flow calculations for fire protection (hydrants) shall be provided per section 18.3 and 18.4 of NFPA 1	Info Only
10.	Public Works - Engineering	Based on the FEMA FIRM Map portion of the site is located in the floodplain - Zone A. The site (Sewer Lift Station) is adjacent to a residential subdivision that was developed around 2010. The FEMA data has not been updated since 2007, so this entire area may have been already taken outside of the floodplain.	Info Only
11.	Public Works - Engineering	The proposed Base Station Antenna technical specifications do not identify the antenna's height. The total height of the proposed structure (the antenna's height plus the pole's height) must be clearly indicated. From available online literature on PCTEL Non Cellular Omnidirectional Base Station Antennas, it appears that these antennas have a height of 4.25 feet and, most likely, do not exceed the height of 5 feet. Per the provided technical specifications for the Round Tapered Direct Burial Aluminum Light Pole, the mounting height of this pole is 40 feet. Therefore, the reviewer anticipates the total height of the proposed structure not to exceed 45 feet above grade. It is not clear if the proposed location of the new structure is within the public "right-of-way" or within the State of Florida DOT property. The location of the new structure is in close proximity to a residential development to the	Info Only

# AGENCY/DEPARTMENT EFORM COMMENTS AND PROJECT STATUS

This section shows the reviewers of this project from the various County agencies. It may also include additional comments for review and response.

DEPARTMENT	REVIEWER
Planning and Development	Kathy Hammel <u>khammel@seminolecountyfl.gov</u>
Public Safety - Fire Marshal	Matthew Maywald <u>mmaywald@seminolecountyfl.gov</u>
Buffers and CPTED	Maya Athanas <u>mathanas@seminolecountyfl.gov</u>
Environmental Services	James Van Alstine <u>jvanalstine@seminolecountyfl.gov</u>
Public Works - Engineering	Vladimir Simonovski <u>vsimonovski@seminolecountyfl.gov</u>
Natural Resources	Sarah Harttung sharttung@seminolecountyfl.gov
Public Works - Impact Analysis	William Wharton www.arton@seminolecountyfl.gov
Comprehensive Planning	Tyler Reed treed@seminolecountyfl.gov
Building Division	Jay Hamm jhamm@seminolecountyfl.gov

#### RESOURCE INFORMATION

#### **Seminole County Land Development Code:**

http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/codes-regulations/

### **Seminole County Comprehensive Plan:**

http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/codes-regulations/comprehensive-plan/index.stml

#### **Development Services:**

http://www.seminolecountyfl.gov/departments-services/development-services/

### Wekiva Consistency form:

http://www.seminolecountyfl.gov/core/fileparse.php/3207/urlt/WekivaConReview.pdf

### **Seminole County Property Appraiser Maps:**

http://www.scpafl.org

## **Seminole County Wetland Information:**

http://www.seminolecountyfl.gov/departments-services/development-services/planning-development/forms-applications-resources/wetl-dock-information.stml

### FEMA LOMR (Letter of Map Revision):

www.fema.gov

#### Cities:

Altamonte Springs	(407) 571-8000	www.altamonte.org
Casselberry	(407) 262-7700	www.casselberry.org
Lake Mary	(407) 585-1449	www.lakemaryfl.com
Longwood	(407) 260-3440	www.longwoodfl.org
Oviedo	(407) 971-5555	www.cityofoviedo.net
Sanford	(407) 688-5000	www.sanfordfl.gov
Winter Springs	(407) 327-1800	www.winterspringsfl.org

#### Other Agencies:

Florida Dept of Transportation	FDOT		www.dot.state.fl.us
Florida Dept of Enviro Protection	FDEP	(407) 897-4100	www.dep.state.fl.us
St. Johns River Water Mgmt Dist	SJRWMD	(407) 659-4800	www.sjrwmd.com
Health Department	Septic	(407) 665-3621	

#### Other Resources:

Flood Prone Areas <u>www.seminolecountyfl.gov/gm/building/flood/index.aspx</u>

Watershed Atlas www.seminole.wateratlas.usf.edu

Seminole Co. Property Appraiser <u>www.scpafl.org</u>

Printed: 3/21/24 3:22 PM Page 5 of 5